



Hilti Aktiengesellschaft, FL-9494 Schaan, Fürstentum Liechtenstein

Unser Zeichen
Our ref.

NAIr

Abteilung
Department

Business Unit Installation Systems

NA Code & Approval

30.11.2019

**Confirmation regarding published
technical data of Hilti pipe ring MP-
SRNI**

Dear Madam and Sir,

we can confirm that the Institute for Building Materials, Solid Construction and Fire Protection (IBMB) of the MPA Braunschweig has carried out load tests with Hilti pipe ring MP-SRNI.

Based on these test results, we can confirm the following load data.

**Bestätigung der veröffentlichten
Technischen Daten der Hilti
Rohrschelle MP-SRNI**

Sehr geehrte Damen und Herren,

wir können bestätigen, dass das Institut für Baustoffe, Massivbau und Brandschutz (IBMB) der MPA Braunschweig Belastungstests mit Hilti Rohrschelle MP-SRNI durchgeführt hat.

Auf Basis dieser Testergebnisse können wir die nachfolgenden Lastdaten bestätigen.

Clamping range	Cross section	Thread	Clamping screw	Tightening torque	Maximum load
15 - 37 mm	17,5 x 2 mm	M8	M6	2 Nm	1300
38 - 64 mm	17,5 x 2 mm	M10	M8	3 Nm	1600

The tests were conducted in January 2010 and February 2014, respectively.

Die Tests wurden im Januar 2010 bzw. Februar 2014 durchgeführt.

Stefan Boenig
Head of Code & Approval

Rainer Loose
Code & Approval Expert