

eco-INSTITUT, Schanzenstr. 6-20, D-51063 Köln

Hilti Entwicklungsgesellschaft mbH
 Mrs. Sarah Kretschmer
 Hiltistraße 6
 86916 Kaufering

Dear Mrs. Kretschmer,

based on the evaluation of the Test Reports No. 60079-A001-CS-L and 60079-A001-L dated 2025-07-14, the testing results of the product **CFS-EOS WS** commissioned by **Hilti Entwicklungsgesellschaft mbH** comply with the requirements of

- VOC product emissions acc. to California Department of Public Health (CDPH) Standard Method v1.2-2017 (California Specification 01350 (01/2017))
- VOC content ASTM D2369-24:2024-07 and South Coast Air Quality Management District (SCAQMD) Rule 1168, 10/2017

These criteria meet the requirements for low-emitting **Adhesives and Sealants** in credit EQc2 of the LEEDv4 Rating System and the LEEDv4.1 Rating System as well as credit MRc3 of the LEEDv5 Rating System.

Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:

Exposure Scenario	Individual VOCs of Concern		Formaldehyde		TVOC (ISO 16000-6)
	Requirement	Requirement hold	Requirement	Requirement hold	
School Classroom	½ CREL	yes	≤ 9 µg/m³	yes	≤ 0.5 mg/m³
Private Office	½ CREL	yes	≤ 9 µg/m³	yes	≤ 0.5 mg/m³

Application amount: 2640 g/m²

VOC content	VOC Limit Value*
110 g/L	250 g/L

* VOC Limit Value for "All Other Sealants" (SCAQMD 1168, 10/2017)

Cologne, 2025-07-17



Marc-Anton Dobaj, M.Sc. Crystalline Materials
 (Project manager)